

5.6.13 Main Commercial Heating and Cooling Equipment as of 1995 and 1999 (percent of total floorspace) (1)

<u>Heating Equipment</u>	<u>1995</u>	<u>1999</u>	<u>Cooling Equipment</u>	<u>1995</u>	<u>1999</u>
Packaged Heating Units	29%	38%	Packaged Air Conditioning Units	45%	54%
Boilers	29%	29%	Individual Air Conditioners	21%	21%
Individual Space Heaters	29%	26%	Central Chillers	19%	19%
Furnaces	25%	21%	Residential Central Air Conditioners	16%	12%
Heat Pumps	10%	13%	Heat Pumps	12%	14%
District Heat	10%	8%	District Chilled Water	4%	4%
Other	11%	6%	Swamp Coolers	4%	3%
			Other	2%	2%

Note(s): 1) Heating and cooling equipment percentages of floorspace add to over 100% since equipment shares floorspace.

Source(s): EIA, Commercial Building Characteristics 1995, October 1998, Tables B34 and B36 for 1995, and EIA, Commercial Building Characteristics 1999, August 2002, Tables B33 and B34 for 1999.